

LEGEND + ABBREVIATIONS

- EXISTING TO REMAIN UON

(ER) EXISTING TO BE REMOVED AND REPLACED WITH NEW AS SHOWN

NEW AS SHOWN, SEE APPROPRIATE SYMBOL BELOW

- EXISTING TO BE RELOCATED AS SHOWN, SEE PLAN

⇌ DUPLEX RECEPTACLE

2-DUPLEX RECEPTACLE

WIRE/RACEWAY: "HOMERUN", MIN SIZE #12 SEPARATE NEUTRAL FOR EACH CIRCUIT COMMON PARITY GROUND IN 3/4" C UON

ABOVE FINISHED FLOOR AFF UNLESS OTHERWISE NOTED UON

① SHEETNOTE IDENTIFICATION TAG

B FIRE ALARM BELL

FIRE ALARM BELL WITH STROBE LIGHT

(V) FIRE ALARM STROBE LIGHT

SCALE: 1/16"=1"-0"

SHEET NOTES:

1 FIELD CURRENT MEASUREMENT IN THE EXISTING BELL CNT (FAP-001-71, MODULE22, CP-30) IS 0.85AMP, INSTALL (1)-PREZAMM BELL TAP TO THE NEZMEST FIRE BELL AS SHOWN, (NEW CURRENT 0.85+0.070-0.72AMP) REPER TO PIRE ALAMIS STERE BUIL AS PROPOSO. TEST UPON COMPLETION.

GENERAL NOTES

- 1 ALL ELECTRICAL EQUIPMENT, DEVICES & INSTALLATION SHALL COMPLY WITH LBNL ELECTRICAL STANDARDS/SPECIFICATIONS & LATEST EDITION OF NEC.
- 2 PRIOR TO CONSTRUCTION FIELD VERIFY & CHECK EXISTING CONDITIONS, ELEVATIONS, DIMENSIONS AND INFORM ENGINEER/CONSTRUCTION SUPERINTENDANT OF CONFLICTS, INTERFERENCES & UNEXPECTED CONDITIONS.
- 3 CONDUIT & WIREWAY ROUTING ARE DIAGRAMATIC. MINIMUM SIZE OF CONDUIT IS 3/4" & #12AWG FOR WIRE. SUPPORT CONDUITS & WIREWAY AT LEAST EVERY 10 FEET OR AS REQUIRED.
- 4 FIELD TO VERIFY & CHECK EQUIPMENT RATING, INTERCONNECTIONS, PRIOR TO TIE-DOWNS.
- 5 TAG & LABEL ALL ELECTRICAL EQPT & DEVICES WITH CIRCUIT NOs. AND/OR EQUIPMENT NOs.
- 6 FIELD TO SUBMIT MARKED-UP PRINTS AFTER THE INSTALLATIONS COMPLETE FOR "AS-BUILT".
- 7 SEAL ALL CONDUIT PENETRATIONS WITH LBNL APPROVED FIRE SEALANT.

